

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

December 1, 2012

TITLE OF DOCUMENT (new title if applicable):

Grounding and Bonding for Electrical Systems, 26 05 26

DATE OF VERSION BEING SUPERSEDED (old):

September 1, 2010

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Grounding and Bonding for Electrical Systems, 26 05 26

SUMMARY OF CHANGES IN THIS VERSION:

1. Updated publications for ASTM, IEEE, NFPA and UL under Article 1.5 Applicable Publications to reflect latest publication year.
2. Added reference to publication document NFPA 70E-12 under Article 1.5 Applicable Publications.
3. Added requirement to allow bonding conductors to be stranded for final connection to motors, transformers and vibrating equipment under Article 2.1 Grounding and Bonding Conductors.
4. Added clarification to allow stainless steel ground rods as an option under Article 2.2 Ground Rods.
5. Added Article 3.14 Acceptance Checks and Tests to spec. section.