

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

December 1, 2012

## **TITLE OF DOCUMENT (new title if applicable):**

Underground Electrical Construction, 26 05 41

## **DATE OF VERSION BEING SUPERSEDED (old):**

September 1, 2010

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Underground Electrical Construction, 26 05 41

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. Updated publications for ACI, ANSI, ASTM, NEMA, NFPA and UL under Article 1.5 Applicable Publications to reflect latest publication year.
2. Added requirement for the option to install GFCI receptacle, cord and plug connected to sump pump with float switch and with thermal overload protection under Article 3.1 Manhole and Pullbox Installation
3. Edited requirement to allow plastic utility duct or PVC if the installation under an existing paved area or road is bored. See Article 3.2 Trenching