


NOTES:
 1. ALL DUCTWORK IS STAINLESS STEEL

SUPPLY DUCT DETAIL - OPERATING ROOM



NTS

DESIGNERS NOTES:
 1. PROVIDE 2 FULL CROSS SECTIONS THRU EACH OR.



Department of
 Veterans Affairs

DETAIL TITLE / SUPPLY DUCT TAKEOFF DETAIL - OPERATING ROOM

SCALE : NONE

DATE ISSUED : DECEMBER 2008

CADD DETAIL NO. : SD233100-25.DWG