

DENTAL AIR (DA) ALARM PANEL SCHEDULE

LOCATION	TYPE OF PANEL	GAGES	SERVICE INDICATOR LIGHTS
BOILER PLANT CONTROL OFFICE -OR- ENGINEERING CONTROL CENTER (ECC) -OR- OTHER LOCATION WITH ENGINEERING PERSONNEL SUPERVISION -AND- DENTAL RECEPTION AREA	MASTER (SYSTEM) ALARM PANEL	NO	DENTAL AIR (DA) DEW POINT HIGH DA FILTER PRESS DROP HIGH DA HIGH TEMP SHUTDOWN DA LOW LUBRICANT DA CARBON MONOXIDE LEVEL HIGH DA LINE PRESSURE LOW DA LINE PRESSURE HIGH DESICCANT DRYER MALFUNCTION TEST BUTTON

NOTES TO DESIGNER:

1. LOCATE MASTER ALARM PANELS IN CONFORMANCE WITH INDIVIDUAL MEDICAL CENTER'S OPERATING PRACTICES FOR CRITICAL ALARM LOCATIONS.
2. INDICATE ROOM NUMBERS WHERE PANELS ARE TO BE LOCATED.



Department of
Veterans Affairs

DETAIL TITLE / DENTAL AIR ALARM PANEL SCHEDULE

SCALE :NONE

DATE ISSUED: JULY 2014

CAD DETAIL NO.: SD226119_74-01.DWG