


SCHEDULE		
SIZE OF PIPE INCH [mm]	SIZE OF "U" BOLT INCH [mm]	SIZE OF CHANNEL INCH [mm]
1 - 2 [25 - 50]	3/8 [10] DIA.	6 x 10.5 [150x265]
2-1/2 - 5 [65 - 125]	1/2 [15] DIA.	8 x 13.75 [200x345]
6 - 8 [150 - 200]	3/4 [20] DIA.	10 x 20 [250x500]

SCHEDULE FOR 8 FT. [2.4m] SPAN OR LESS.

ANCHOR INSTALLATION STEAM/CONDENSATE PIPING IN TRENCH



NTS



Department of
Veterans Affairs

DETAIL TITLE / ANCHOR INSTALLATION -
STEAM/CONDENSATE PIPING IN TRENCH

SCALE :NONE

DATE ISSUED :DECEMBER 2008

CADD DETAIL NO. : SD230511-28.DWG