



NOTES:

1. PROVIDE LOW WATER LEVEL ALARM. PROVIDE A LOW WATER LEVEL AT ECC. RELIEF VALVE DRAIN SHALL RETURN TO TANK AS SHOWN ON THIS DETAIL.
2. SET REGULATING VALVE TO MAINTAIN MAKE-UP PRESSURE AT 15 PSIG [103 kPa] ABOVE HIGHEST SYSTEM PRV SETTING.
3. MAKE-UP PIPING SYSTEM DOES NOT REQUIRE INSULATION.
4. OPERATE PUMP MANUALLY AS REQUIRED TO FILL.

INDIRECT GLYCOL MAKE-UP SYSTEM (PIPING AND CONTROLS)

#

NTS

DESIGNER'S NOTE:

PLUMBING DRAWINGS SHOULD INCLUDE DOMESTIC COLD-WATER HOSE BIB NEAR THE GLYCOL-WATER MAKE-UP SYSTEM. FOR SMALL SYSTEMS (50 GAL [200 L] OR LESS) A POT FEEDER, AT THE HIGH POINT IN THE PIPING, MAY BE USED FOR MAKE-UP IN LIEU OF THE PUMPED MAKE-UP.



Department of
Veterans Affairs

DETAIL TITLE / INDIRECT GLYCOL MAKE-UP SYSTEM
(PIPING AND CONTROLS)

SCALE :NONE

DATE ISSUED :MARCH 2010

CADD DETAIL NO. : SD232113-06.DWG