


NOTE:

1. PROVIDE IN CHILLED WATER MAIN AND IN CONDENSER WATER MAIN.
2. LOCATE PILOT TUBE TAPS 20 PIPE DIAMETERS DOWNSTREAM AND 10 PIPE DIAMETERS UPSTREAM FROM THE NEAREST PIPE FITTING.

EITHER TOP OR SIDE LOCATION. BOTH ARE NOT REQUIRED AT SAME LOCATION.



PITOT TEST CONNECTIONS

NTS

DESIGNER'S NOTE:

SHOW LOCATION OF PILOT TEST CONNECTIONS ON FLOOR PLANS FOR CONDENSER WATER PIPING TO COOLING TOWER. THIS IS REQUIRED FOR FLOW MEASUREMENT BY ASME COOLING TOWERS TEST CODE.



Department of
Veterans Affairs

DETAIL TITLE / PITOT TEST CONNECTIONS

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.:

SD232113-13.DWG