


# WATER FILTERS - CLOSED LOOP HYDRONIC SYSTEMS



NTS

**DESIGNER'S NOTE:**

1. PROVIDE SEDIMENT WATER FILTER ON EACH CHILLED WATER, HOT WATER AND GLYCOL WATER HEATING SYSTEM. CAPACITY SHALL BE APPROXIMATELY 5% OF THE TOTAL CIRCULATING FLOW. SHOW FILTER LOCATIONS ON THE DRAWINGS. INCLUDE THE FILTER FLOW RATE IN PUMP CAPACITIES. SIZE PIPES TO WATER FILTER.
2. SELECT PRESSURE RANGE PER PROJECT NEED. SPECIFY PRESSURE RANGE ON DRAWINGS.



Department of  
Veterans Affairs

DETAIL TITLE / WATER FILTERS -  
CLOSED LOOP HYDRONIC SYSTEMS

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD232500-01.DWG