


NOTE:

1. PROVIDE BRACING TO LIMIT THE AMPLITUDE OF WALL VIBRATION AND WALL DEFLECTION TO SPECIFIED MAXIMUMS.
2. MINIMUM BRACING REQUIREMENTS:

<u>MAXIMUM DUCT WIDTH</u> IN. [mm]	<u>MAXIMUM SIZE ANGLE</u> IN. [mm]	<u>MAXIMUM SPACING</u> IN. [mm]
UP TO 26 [650]	NONE	
27 [675] TO 40 [1000]	1-1/2x1-1/2x3/16 [40x40x7]	72 [1800]
41 [1000] TO 60 [1500]	2x2x3/16 [50x50x7]	48 [1200]
61 [1500] TO 72 [1800]	2x2x3/16 [50x50x7]	24 [600]

3. INSULATION: FOR COLD DUCTS INSULATE BRACES AND PROVIDE VAPOR BARRIER.



FLAT OVAL DUCT HANGERS/REINFORCEMENT

NTS



Department of
Veterans Affairs

DETAIL TITLE / FLAT OVAL DUCT HANGERS/REINFORCEMENT

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD233100-13.DWG