



**NOTE:**  
 THE USE OF FLEXIBLE AIR DUCT CONNECTORS ARE NOT PERMITTED FOR THE DEDICATED AHU SERVING THE SURGICAL SUITE.

# **FLEXIBLE AIR DUCT CONNECTOR**  
 NTS