



AIR COOLED CHILLER - PIPING CONNECTIONS

NTS

DESIGNER NOTE:

1. PROVIDE HEAT TRACING WHEN THE EXPOSED PIPING CARRYING CHILLED WATER IS NOT MIXED WITH PROPYLENE CLYCOL. ALL VALVES, STRAINER, FLOW SWITCH, FLEXIBLE CONNECTORS, ETC., SHALL BE WRAPPED WITH ELECTRIC HEAT TRACE CABLE UNDER INSULATION.
2. VERIFY NEED FOR FLEXIBLE CONNECTOR.
3. PROVIDE ALUMINUM JACKETING ON ALL EXPOSED, INSULATED PIPING.



Department of
Veterans Affairs

DETAIL TITLE / AIR COOLED CHILLER -
PIPING CONNECTIONS

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD236400-01.DWG