

NTS

#

AIR INTAKE FOR MISSION CRITICAL FACILITIES, SEE VA STANDARD DETAILS.

RETURN AIR INTAKE.

ACCESS DOOR SWING DETAIL FOR AIR HANDLING UNITS

SS DOORS SHALL BE IST FAN OPERATING UM ACCESS DOOR W SS DOOR HEIGHT SH NOT TO EXCEED 6'-(SS DOORS ON FAN SS DOORS ON FAN

16

 _	_		2)	345	6789		12 13	14 15
 			COIL	PULL DISTANCE	УУ 			
		AIR HANDLING UNIT	ITEM	MINIMUM OUTSIDE AIR TWO BEDS OF FILTERS VAV	MINIMUM OUTSIDE AIR THREE BEDS OF FILTERS CV	100% OUTSIDE AIR TWO BEDS OF FILTERS CV		
	*	MIXING BOX	1	YES	YES	NO	NO	1
	*	BLENDER SECTION	2	YES	YES	NO	NO	
		PRE-FILTERS (SIDE ACCESS)	3	YES	YES	YES	YES	
		INSPECTION SECTION, SMALL	4	YES	YES	YES	YES	
		AFTER FILTER (SIDE ACCESS)	5	YES	YES	YES	YES	
		ACCESS SECTION, MED-LARGE	6	YES	YES	YES	YES	
	*	HEAT RECOVERY COIL	7	NO	NO	YES	YES	
	*	ACCESS SECTION, MED-LARGE	8	NO	NO	YES	YES	
	*	PRE-HEAT COIL	9	YES	YES	YES	YES	
	*	INSPECTION SECTION,SMALL	10	YES	YES	YES	YES	
		HUMIDIFIER	11	YES	YES	YES	YES	
		COOLING COIL	12	YES	YES	YES	YES	
		FAN	13	YES	YES	YES	YES	NOTE:
	*	DIFFUSER PLATE	14	NO	NO	NO	YES	
	*	ACCESS SECTION,MED-LARGE	15	NO	NO	YES	YES	1. ACCESS AGAINS
	*	HEPA FILTER	16	NO	NO	NO	YES	2. MINIMU
	*	DISCHARGE PLENUM (VERTICAL)	17	YES	YES	YES	YES	3. ACCESS BUT NO
				* AS	REQUIRED			4. ACCESS
								5. ACCES

MIN CLEARANCE - 36"

	Detail title / access door swing detail for air handling units	SCALE : NONE	DATE ISSUED: DECEMBER 2008 CAD DETAIL NO.: SD237300-01.DWG
BE GASKETED AND HINGED TO OPEN G PRESSURE TO PREVENT AIR LEAKAGE. R WIDTH SHALL BE 24" [600mm]. SHALL BE DETERMINED BY UNIT CASING S'-O" [1800mm]. N SUCTION SHALL OPEN OUTWARD. N DISCHARGE SIZE SHALL OPEN INWARD.	Department of Veterans Affairs		
S/ELEVATIONS OF THE			