



NOTE:

1. TOP OF CURB (TC) AND TOP OF RAMP ELEVATIONS SHOWN ARE IN RELATION TO THE GUTTER AND ARE LOCATED RADIALLY. GUTTER = 0"
2. SEE STANDARD VA DETAIL 32 05 23-18 "CONCRETE SIDEWALK" FOR JOINT REQUIREMENTS.
3. WHEN CURB HEIGHTS OF GREATER THAN 7" [180mm] ARE SHOWN ON PLANS, SEE PLANS AND ADA REQUIREMENTS.
4. LANDING RAMP AREA TO BE STANDARD ON ALL PROJECTS. TYPE 2 CURB WITH 6" [152mm] REVEAL OR BARRICADE RAILING REQUIRED ONLY WHEN NOTED ON THE PLANS IN ORDER TO RESTRICT VEHICULAR TRAFFIC.

CURB ACCESS RAMP
NTS