

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

June 1, 2015

TITLE OF DOCUMENT:

Wet-Pipe Sprinkler Systems, 21 13 13

DATE OF VERSION BEING SUPERSEDED (old):

May 1, 2008

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Wet-Pipe Sprinkler Systems, 21 13 13

SUMMARY OF CHANGES IN THIS VERSION:

1. Added requirement for valve tags and valve charts for operational issues.
2. Updated fire department connection criteria to allow for Storz connections that are now being utilized by local fire department in many jurisdictions.
3. Coordinated submittal requirements with fire pumps sections and the dry-pipe sprinkler system section.