

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

September 1, 2015

TITLE OF DOCUMENT (new title if applicable):

Facility Water Distribution, 22 11 00

DATE OF VERSION BEING SUPERSEDED (old):

January 1, 2014

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Facility Water Distribution, 22 11 00

SUMMARY OF CHANGES IN THIS VERSION:

1. 1.2 - Added spec sections to related work.
2. 1.3 - Added references and updated applicable publications to their latest versions.
3. 1.5.D - Added Bio-Based Materials.
4. 1.7.B - Revised to exclude damper and door closure interlocks.
5. 1.7.D - Revised to include documentation on Certifier's Letterhead if certificate is not available.
6. 2.2.B - Revised to include the "pressure class" in lieu of "water steam pressure".
7. 2.3.B.3 - Revised to include NSF reference.
8. 2.3.D - Revised joining method for adapters.
9. 2.3.F. - Revised to include brazing alloy for copper-copper and copper-steel joints.
10. 3.1.A.5.C.10 - Revised description of insulation shields.
11. 3.1.A.8. - Revised mechanical press-connect fittings joining methods