

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

September 1, 2015

## **TITLE OF DOCUMENT (new title if applicable):**

Reverse-Osmosis Water Equipment, 22 67 19.16

## **DATE OF VERSION BEING SUPERSEDED (old):**

February 1, 2011

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Reverse-Osmosis Water Equipment, 22 67 19.16

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. 1.2 – Updated specification sections with related work
2. 1.3 – Revised applicable publications to their latest versions
3. 1.4.F - Added submittals for training plans and instructor qualifications
4. 1.5.B – Added Bio-Based Materials.
5. 1.6.A. - Added Spec Writer Note: Designer to confirm water quality with boiler manufacturer.
6. 2.1 B.2 - Revised capture rate performance requirement numbers to 75% and 25%.
7. 2.1 I.1 - Added DDC selection for electronic controller.
8. 2.1 I.9 - Noted quantity of auxiliary contacts for miscellaneous controls.
9. 2.1L.1 - Clarified that factory authorized technical representative shall test equipment that requires field reassembly.