

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

**DATE OF THIS VERSION:**

July 1, 2023

**TITLE OF DOCUMENT:**

Applied Fireproofing, 07 81 00

**DATE OF VERSION BEING SUPERSEDED (old):**

October 1, 2017

**DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Applied Fireproofing, 07 81 00

**SUMMARY OF CHANGES IN THIS VERSION:**

1. Removed all references that allowed for the use of Type II Mineral Fiber Applied Fireproofing as a fire resistant option.