

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

August 1, 2017

## **TITLE OF DOCUMENT (new title if applicable):**

Common Work Results for HVAC, 23 05 11

## **DATE OF VERSION BEING SUPERSEDED (old):**

February 1, 2015

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Common Work Results for HVAC, 23 05 11

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. 1.1 C updated list of abbreviations and acronyms and coordinated that with the plumbing specifications.
2. 1.2 – Updated references specification section.
3. 1.3 – Updated applicable publications section and verified most recent versions of the publications on the list.
4. Changed all references of “Resident Engineer” to “COR.”
5. 1.6 A -2 Added paragraph to require winter time protection from road salts and other pollutants by requiring equipment to be shipped in closed trucks or shipped with protective tarpaulin.
6. 1.7 Added spec writer’s note to coordinate as-built drawings with General Requirements section. Also added quality control requirements to improve the chances of getting accurate as-built documents.

7. 2.3 Added paragraph J to clarify that final drive set is to be provided by the Contractor.
8. 2.4 Added new paragraph for specifying synchronous (no slip) belt drives for systems with variable speed drives.
9. 2.8 Made changes so that the specification of variable speed motor controllers rest in division 26.
10. Added 2.9 F ceiling grid labels for identification of above ceiling components.
11. Added 3.7 D for the required use of ceiling grid labels.
12. Added 3.8 for the application of synchronous belt drives.