

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

August 1, 2017

## **TITLE OF DOCUMENT (new title if applicable):**

Noise and Vibration Control For Boiler Plant 23 05 51

## **DATE OF VERSION BEING SUPERSEDED (old):**

February 1, 2015

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Noise and Vibration Control For Boiler Plant 23 05 51

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. This section is a complete re-write. This was accomplished by taking section 23 05 41 Noise and Vibration Control for HVAC Piping and Equipment and deleting all paragraphs / information that is not applicable to boiler plants – I.E. chillers, cooling towers etc.
2. Updated references and applicable publications.
3. The section now includes product and application specifications for vibration isolators, isolation hangers, and seismic bracing. It also includes noise criteria for spaces found in boiler plants and vibration control equipment application table.
4. Added alignment and testing requirements to Part 3.