

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

August 1, 2017

TITLE OF DOCUMENT (new title if applicable):

23 22 23 - STEAM CONDESATE PUMPS

DATE OF VERSION BEING SUPERSEDED (old):

February 1, 2015

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

23 22 23 - STEAM CONDESATE PUMPS

SUMMARY OF CHANGES IN THIS VERSION:

1. Added Par. 1.1.B.
2. Relocated Applicable Publications, Quality Assurance, Submittals .
3. Par 1.3.D. Added “//and if specified, for dual parallel pump operation//.”
4. Par 1.4.B.5. Added “electric-powered”.
5. General: Replaced “Resident Engineer” with “COR”.
6. Added Spec Writer Note to par 2.1.
7. Changed par 2.1.F.1 from NEMA 1 to NEMA 4 enclosure.
8. Changed par 2.1.G from NEMA 1 to NEMA 4 enclosure.
9. Changed par 2.2.G from NEMA 1 to NEMA 4 enclosure.
10. Changed par 2.3.F from NEMA 1 to NEMA 4 enclosure.
11. Par 2.1.F.2., 2.2.G.2, Added “to equalize wear”.

12. Par 2.1.G., 2.2.G, Replaced “horsepower” with HP.
13. Par 2.4.A.1 Added “not less than”.
14. General: Put metric units ahead of English units.
15. Par 2.4.A.2.e. Added “Pipe material and schedule shall comply with Section 23 22 13,
STEAM AND CONDENSATE HEATING PIPING.”
16. Par 2.4.A.2.f. Added “Digital”.
17. Added Par 2.4.A.2.g.7.
18. Deleted Par 3.1.B. “Permanently support...”.