

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

August 1, 2017

TITLE OF DOCUMENT (new title if applicable):

23 51 00 – BREECHINGS, CHIMNEYS AND STACKS

DATE OF VERSION BEING SUPERSEDED (old):

May 1, 2011

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

23 51 00 – BREECHINGS, CHIMNEYS AND STACKS

SUMMARY OF CHANGES IN THIS VERSION:

1. Par 1.2. Added other Sections.
2. Relocated Applicable Publications, Quality Assurance.
3. Par 1.4.B. added “//Structural //”.
4. Par 1.4.D. added “material specifications”.
5. General: Replaced “Resident Engineer” or “COTR” with “COR”.
6. Updated Applicable Publications and added new ones.
7. Par 1.5.E. added “sizing, design of flue gas vents, and”.
8. Added Par 1.5.F.
9. Par 2.1.A. added “FGR ductwork construction, material and gage thickness shall be the same as in the main chimney/stack.”
10. Par 2.1.B. modified to read as “.., for a wind-loading for outside stacks of // //...”

11. Par 2.1.D.4. replaced "Manual of Steel Construction, "Design, Fabrication, and Erection of Structural Steel" with "325".
12. Par 2.4.B.1., 2.4.B.2 Added "//NOx//".
13. Added Apr 2.6. and 2.7.
14. Par 3.2.C. Deleted "Plumbing".
15. Added Par 3.3 "INSTALLATION OF VENT FOR CONDENSING APPLIANCES".
16. General Note: No. 5 and No. 6 fuel oil have been removed from all steam specifications.