

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

January 1, 2017

TITLE OF DOCUMENT:

Medium –Voltage Cables, 26 05 13

DATE OF VERSION BEING SUPERSEDED (old):

December 1, 2012

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Medium –Voltage Cables, 26 05 13

SUMMARY OF CHANGES IN THIS VERSION:

1. Section 1.3: Revised to provide clarity.
2. Section 1.4(A) & (B): Revised to provide clarity to factory testing requirements.
3. Section 1.5(A), (A)(2) & A(4): Revised to provide clarity to samples, and additional requirement for qualified workers who perform testing.
4. Section 1.6: Revised to show latest applicable publications.
5. Section 1.7(A): Revised to provide clarity.
6. Section 2.1(D)(2)(b): Revised to include cable type TR-XLPE.
7. Section 3.4(B): Revised to provide clarity.
8. Section 3.7: Revised to edit the entire section. Revised to delete On-line Partial Discharge test, and to include Tan Delta and VLF Withstand tests.