

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

December 1, 2015

TITLE OF DOCUMENT:

Low-Voltage Transformers, 26 22 00

DATE OF VERSION BEING SUPERSEDED (old):

August 1, 2014

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Low-Voltage Transformers, 26 22 00

SUMMARY OF CHANGES IN THIS VERSION:

1. Section 1.5: Revised Application Standards to reflect latest editions. Revised to delete the rescinded NEMA TP 1. Revised to include Department of Energy (DOE) 10 CFR Part 431.
2. Section 2.1 B-7: Revised to delete sound level table. Revised to require average sound level to comply with NEMA standard.
3. Section 2.1 B-14: Revised to delete the rescinded NEMA TP 1 and its requirements. Revised to include the requirement per DOE's 10 CFR 431.
4. Section 2.2 D: Revised to delete the harmonic table. Edited the requirements to provide clarity.