

PIPING SYMBOLS

—————S-60—————	HIGH PRESSURE STEAM (60 PSIG AND ABOVE)
-----CR-60-----	HIGH PRESSURE STEAM CONDENSATE RETURN
—————S-30—————	MEDIUM PRESSURE STEAM (16 PSIG THRU 59 PSIG)
-----CR-30-----	MEDIUM PRESSURE STEAM CONDENSATE RETURN
—————S-15—————	LOW PRESSURE STEAM (15 PSIG AND BELOW)
-----CR-15-----	LOW PRESSURE STEAM CONDENSATE RETURN
—————PC—————	CONDENSATE PUMP DISCHARGE
—————HWS—————	HOT WATER HEATING SUPPLY
-----HWR-----	HOT WATER HEATING RETURN
—————GHS—————	GLYCOL-WATER HEATING SUPPLY
-----GHR-----	GLYCOL-WATER HEATING RETURN
—————SWS—————	SOLAR WATER SUPPLY
-----SWR-----	SOLAR WATER RETURN
—————RL—————	REFRIGERANT LIQUID
—————RS—————	REFRIGERANT SUCTION
—————RHG—————	REFRIGERANT HOT GAS
—————CWS—————	CONDENSER WATER SUPPLY (FROM TOWER)
-----CWR-----	CONDENSER WATER RETURN (TO TOWER)
—————CHS—————	CHILLED WATER SUPPLY
-----CHR-----	CHILLED WATER RETURN
—————GCS—————	CHILLED GLYCOL-WATER SUPPLY
-----GCR-----	CHILLED GLYCOL-WATER RETURN
—————MW—————	MAKE-UP WATER
—————D—————	DRAIN LINE
—————V—————	VENT LINE
—————GRS—————	GLYCOL-WATER RUN AROUND SUPPLY
-----GRR-----	GLYCOL-WATER RUN AROUND RETURN
—————X—————	EXISTING PIPE TO BE REMOVED



Department of
Veterans Affairs

DETAIL TITLE: PIPING SYMBOLS

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD230511-14.DWG