


CONTROL SYSTEM CONFIGURATION
 OPTION 4 –
 EXISTING ECC TO REMAIN, INSTALL NEW BACNET SOFTWARE ON EXISTING ECC. EXISTING CONTROL SYSTEM SOFTWARE TO CO-EXIST ON ECC. INSTALL NEW BACNET CONTROLS ON CURRENT PROJECT, EXISTING CONTROL SYSTEM TO REMAIN, RE-USE EXISTING COMMUNICATION NETWORK.

- NOTES:
1. INSTALL NEW BACNET SOFTWARE ON EXISTING ENGINEERING CONTROL CENTER (ECC.)
 2. REUSE EXISTING COMMUNICATION NETWORK.
 3. EXISTING CONTROLLERS TO REMAIN.
 4. INSTALL MULTIPLE BUILDING CONTROLLERS AS REQUIRED.
 5. INSTALL NEW CONTROLLERS (B-AAC, B-ASC) AS REQUIRED,
 6. PROVIDE NEW PORTABLE OPERATORS TERMINAL.



BACNET SYSTEM ARCHITECTURE OPTION 4

NTS

DETAIL TITLE / BACNET SYSTEM ARCHITECTURE OPTION 4

Department of
Veterans Affairs



SCALE : NONE

DATE ISSUED: SEPTEMBER 2010

CAD DETAIL NO.: SD230923-14.DWG