


NOTES:

1. UNLESS OTHERWISE SHOWN ON THE DRAWINGS, SIZE THE VENT PIPE SO THAT STEAM IS NOT BLOWN OUT AT THE VENT PIPE ENTRANCE. UTILIZE THE CALCULATION METHOD CONTAINED IN ANSI B31.1. POWER PIPING CODE, APPENDIX II.
2. VENT PIPE SHALL TERMINATE 1829mm [6'] MIN. ABOVE FINISHED ROOF.
3. DISCHARGE OF DRAIN SHALL BE DIRECTED AWAY FROM PLATFORMS OR OTHER AREAS WHICH PERSONNEL MAY OCCUPY.
4. NO OTHER DRAIN SHALL BE CONNECTED TO THE DRIP PAN ELBOW DRAIN PIPE.



STEAM SAFETY VALVE

NTS



Department of
Veterans Affairs

DETAIL TITLE: STEAM SAFETY VALVE

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD232111-02.DWG