



NOTE:

SEE MANUFACTURER'S PIPING RECOMMENDATIONS FOR FINAL LAYOUT

DESIGNER NOTE:

PROVIDE ADDITIONAL CONTROLS FOR VAV OPERATION AND FOR PREVENTING OVER SATURATION OF THE SUPPLY AIR.

STEAM HUMIDIFIER - PIPING CONNECTIONS (MULTIPLE DISPERSION TUBES)

#

NTS



Department of
Veterans Affairs

DETAIL TITLE: STEAM HUMIDIFIER - PIPING CONNECTIONS
(MULTIPLE DISPERSION TUBES)

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD232213-07.DWG