



WATER TREATMENT - CLOSED SYSTEMS

NTS

DESIGNER'S NOTE:

1. SHOW LOCATION OF ALL CHEMICAL POT FEEDER TANKS ON PIPING DIAGRAMS FOR EACH CHILLED WATER AND HEATING HOT WATER SYSTEM. FEEDER MAY ALSO BE USED FOR MAKE-UP FOR SMALL GLYCOL-WATER SYSTEMS (UNDER 50 GPM [190 LPM] IN LIEU OF A TANK/PUMP MAKE-UP SYSTEM.



Department of
Veterans Affairs

DETAIL TITLE / WATER TREATMENT - CLOSED SYSTEMS

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD232500-02.DWG