


NOTE:

1. DELETE INSULATION STAND-OFF ON DUCTWORK WITHOUT EXTERIOR INSULATION.
2. DETAIL SHOWS SINGLE BLADE DAMPER. DAMPER INSTALLATION SHALL BE SIMILAR FOR MULTI-BLADE DAMPERS & ROUND DAMPERS.



VOLUME DAMPER DETAIL

NTS



Department of
Veterans Affairs

DETAIL TITLE / VOLUME DAMPER DETAIL

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD233100-08.DWG