


**NOTES:**

1. ALL DUCTS SHALL BE WATER TIGHT WELDED STAINLESS STEEL TO EXHAUST FAN.
2. PITCH DUCTS DOWN TOWARD INTAKE OPENINGS OR PROVIDE DRAIN AT ANY POINT WHERE WATER WILL COLLECT.
3. SEE FLOOR PLANS FOR EXHAUST AIR VOLUME AND DUCT SIZES.



## EXHAUST DUCTWORK - GLASSWASHER

NTS

DESIGNER'S NOTES:

1. DETAIL IS FOR DISHWASHER/GLASSWASHER SEE EQUIPMENT DRAWINGS.



Department of  
Veterans Affairs

DETAIL TITLE / EXHAUST DUCTWORK -GLASSWASHER

SCALE :NONE

DATE ISSUED :MAY 2011

CADD DETAIL NO. : SD233100-17.DWG