


DETAIL KEYNOTES:

1. THE DESIGN AND SUPPORTING DOCUMENTATION FOR THE BLAST RESISTANT CONCRETE WALL SHALL BE COORDINATED AND APPROVED BY A REGISTERED PROFESSIONAL STRUCTURAL ENGINEER SPECIALIZING IN BLAST RESISTANT CONSTRUCTION.
2. LIMIT AIR VELOCITY TO 800 FPM [4.0 m/s] THRU PLENUM.

OUTSIDE AIR INTAKE FOR AIR HANDLER UNIT FOR MISSION CRITICAL FACILITY



NTS



Department of
Veterans Affairs

DETAIL TITLE / OUTSIDE AIR INTAKE FOR AIR HANDLER
UNIT FOR MISSION CRITICAL FACILITY

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD233100-23.DWG