


NOTES:

1. 150mm [6"] PLENUM AS SHOWN SHALL BE SUPPLIED BY MANUFACTURER OF FAN COIL UNIT.
2. SEE DETAIL SD2382216-01 FOR SUPPLY & RETURN PIPING CONNECTIONS.
3. PROVIDE ACCESS FOR FILTER REMOVAL.
4. SEE FAN COIL UNIT SCHEDULE FOR PIPE SIZES.
5. SUPPLY & RETURN GRILLES SHALL BE SIZED TO SUIT CONNECTIONS ON FAN COIL UNIT. DUCTWORK SHALL SUIT GRILLES AND FAN COIL UNIT FURNISHED.



FAN COIL UNIT - HORIZONTAL CONCEALED

NTS



Department of
Veterans Affairs

DETAIL TITLE: FAN COIL UNIT - HORIZONTAL CONCEALED

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD238200-10.DWG