



NOTE:
 SIZE AND SELECT COIL FOR PARALLEL FLOW AND MINIMUM
 TUBE WATER VELOCITY OF .91 M/S [3.0 FPS]

DESIGNER'S NOTE:
 1. COORDINATE WITH HVAC DESIGN MANUAL.
 2. CONSIDER REMOVING MANUAL BYPASS, BECAUSE CONTROL VALVES ARE REASONABLY RELIABLE AND THE PRESENCE OF THE BYPASS MAY ENCOURAGE POSTPONING REPAIRS, THEREBY LESSENING THE EFFECTIVENESS OF VARIABLE SPEED PUMPING SYSTEMS

PREHEAT COIL (HOT WATER) - PIPING CONNECTIONS

#

NTS

DETAIL TITLE: PREHEAT COIL (HOT WATER) - PIPING CONNECTIONS

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD238216-02.DWG