


















ELECTRICAL SYMBOLS - POWER PLAN

	DISTRIBUTION PANEL
	PANELBOARD, FLUSH MOUNTED
	PANELBOARD, SURFACE MOUNTED
	RECEPTACLE, CLOCK HANGER
	RECEPTACLE, DUPLEX
	RECEPTACLE, DUPLEX ON EMERGENCY POWER
	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER
	RECEPTACLE, QUADRUPLEX
	RECEPTACLE, SINGLE
	RECEPTACLE, SINGLE WITH SWITCH
	RECEPTACLE, SPECIAL PURPOSE
	A = 120V, 20A, 1 PHASE, 2-POLE, 3W, NEMA 5-20F
	B = 208V, 20A, 1 PHASE, 2-POLE, 3W, NEMA 6-20F
	C = 120V, 30A, 1 PHASE, 2-POLE, 3W, NEMA 5-30F
	D = 208V, 30A, 1 PHASE, 2-POLE, 3W, NEMA 6-30F
	E = 208V, 60A, 1 PHASE, 3-POLE, 4W, NEMA 14-60
	F = 208V, 30A, 3 PHASE, 3-POLE 4W, NEMA 15-30
	G = 208V, 50A, 3 PHASE, 3 POLE, 4W, NEMA 15-30
	H = 208V, 60A, 3 PHASE, 3 POLE, 4W, NEMA 15-60
	RECEPTACLE, SWITCHED DUPLEX
	DROP CORD, SINGLE CONVENIENCE OUTLET, 3-WIRE, (20A, W/#12 CONDUCTORS IN FLEXIBLE CORD (CENTER TO CENTER) 6'-6" [1981mm] AFF. MINIMUM).
	ELECTRICAL STRIP MOLD (OUTLETS ON 2'-0" [610mm] DESIGNATED ON DRAWINGS), MTD 3'-6" [1067mm] AFF INDICATED.
	DISCONNECT SWITCH, FUSED
	DISCONNECT SWITCH, UNFUSED
	STARTER, COMBINATION WITH DISCONNECT SWITCH