

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

September 1, 2020

TITLE OF DOCUMENT (new title if applicable):

Revisions of selected Plumbing Detail Drawings

DATE OF VERSION BEING SUPERSEDED (old):

July 1, 2014

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Revisions of Plumbing Detail Drawings

SUMMARY OF CHANGES IN THIS VERSION:

1. 22 05 11
 - 01 – Pipe Penetration Through Walls Below Grade – Removed flexible expansion joint and added a note to refer to civil or site plans for thermal expansion loop. (if required)
 - 02 – Plumbing Abbreviations – Update abbreviations to match specifications, details, and design guide. (Typical of three sheets)
 - 05 – Drawing Symbols – Updated symbols to match specifications, details, and design guide.
 - 06 – Plumbing Piping Symbols – Added line type for cold water circulation.
 - 07 – General Plumbing Symbols – Added symbols for hose connection, hose bibb, temperature sensor, and circulating pump.
 - 08 – Plumbing Valve Symbols – Added symbols for balance valve and automatic flow control valve.
2. 22 13 00
 - 01 – Flushing Rim Floor Drain “L” Cystoscopy Room – Modified detailed to simplify installation through the use of a concealed manual flushometer.
 - 02 – Hub Drain with Standpipe – No Change

- 03 – Type “C” Floor Drain Detail – No Change
 - 04 – Type “D” Floor Drain Detail – Added the option for PVC shower pan. Added designer note to coordinate detail with existing floor construction when using for a renovation project.
 - 05 – Type “F” Floor Drain Detail – Added the option for PVC shower pan. Added designer note to coordinate detail with existing floor construction when using for a renovation project.
3. 22 35 00
- 01 – Connection To Domestic Water Heater – Added notes for controls to be electronic and coordination with manufacturer controller and building management system.
 - 02 – Connection To Domestic Water Booster Heater - – Added notes for controls to be electronic and coordination with manufacturer controller and building management system.
4. 22 61 19.74
- Dental Air Alarm Panel
 -