

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

September 1, 2015

TITLE OF DOCUMENT (new title if applicable):

Vacuum Systems for Laboratory and Healthcare Facilities, 22 62 00

DATE OF VERSION BEING SUPERSEDED (old):

August 1, 2012

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Vacuum Systems for Laboratory and Healthcare Facilities, 22 62 00

SUMMARY OF CHANGES IN THIS VERSION:

1. 1.1B - Removed spec writers note.
2. 1.2 - Updated specification sections with related work.
3. 1.3 – Revised applicable publications to their latest versions.
4. 1.4.G - Added system readiness checklist
5. 1.4.H - Added training plan requirements.
6. 1.5.D – Added testing shall be performed by an independent third party testing company.
7. 1.5.F- Spec Writers Note – Noted Design Engineer shall coordinate with COR for amount of time required for shutdown.
8. 1.5.I - Added Bio-Based Materials.
9. 1.7.D – Added certification documentation requirements before final inspection.
10. 2.13.E - Noted drainage system carryover of foreign material shall discharge into sanitary sewer.
11. 2.14.G - Provided option for both ‘PLC’ or ‘DDC’ to be used to implement operating logic of vacuum pumps.
12. 3.1.S - Clarified that a vacuum gage 1-1/2” in diameter shall be installed in line downstream of each valve located in a zone valve cabinet.

13. 3.2. – Updated NFPA references
14. 3.3. – Updated NFPA references
15. 3.5 – Added Commissioning.
16. 3.6 – Added Demonstration and Training.