

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

May 1, 2014

TITLE OF DOCUMENT:

26 09 23, LIGHTING CONTROLS

DATE OF VERSION BEING SUPERSEDED (old):

September 1, 2010

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

26 09 23, LIGHTING CONTROLS

SUMMARY OF CHANGES IN THIS VERSION:

1. Spec Writer Notes: Revised (added and deleted) text.
2. Article 1.3 Submittals: Major text revisions; new request for six copies of listed information.
3. Article 1.5 Applicable Publications: Revised/updated listing and dates.
4. Article 2.1 Electronic Time Switches: Added UL 916; modified voltage range.
5. Article 2.2 Electromechanical-Dial Time Switches: Modified voltage range
6. Article 2.8 Indoor Vacancy Sensor Switch: Added new article.
7. Article 2.10 Lighting Control System – Relay Panel Type: Revised article title; major text added/revision.
8. Article 2.11 Lighting Control System – Distributive Relay Type: Added new article.
9. Article 2.12 Lighting Control System – Circuit Breaker Panel Type: Revised article title.
10. Article 2.13 Lighting Control System – Digital Addressable Lighting Interface (DALI): Added new article.
11. Article 3.4 Instruction: Added new article.